

SAFETY VALVE CERTIFICATE OF TEST

1. SUPPLIED TO

<i>Name</i>	AIRBLAST AUSTRALIA	<i>Purchase Order No</i>		0000108	
<i>Workplace Address</i>	Unit 5, 16-18 Kewdale Road, Kewdale	<i>State</i>	WA	<i>Post Code</i>	6105
			David		08 9451
		<i>Site Contact</i>	Pocock	<i>Phone No</i>	4600

2. SAFETY VALVE DETAILS

Manufacturer	R.Conrader	Serial No	3307.14
Model	SRV390	Condition	New

3. TEST GAUGE

Range	0-2000 (kPa)	Manufacturer	Additel	Model	680	Serial	218130C0025
-------	--------------	--------------	---------	-------	-----	--------	-------------


4. TEST DETAILS

		Comments					Comments		
Compressed Air		N			Lead Sealed		N		
Nitrogen		Y			Locked		Y		
Online		N			Replacement Parts		N		
Serviced		N			Overhauled		N		
Pre Set Pressure	N/A (kPa)	Req'd Set Pressure	1000 (kPa)	Final Set Pressure	1000 (kPa)	Final Reseat Pressure	980 (kPa)	Leak Rate @ 90%	0 (bpm)

5. COMMENTS

The safety valve complies with the set pressure tolerance.
The safety valve adjustment has been locked to prevent alteration of the set pressure.
Testing and repairs have been carried out with reference to AS1271-2003

6. DECLARATION

Print Name	Ed Baxter	Signature		Date	05-10-18
				Job No	3307